



STATE PROCUREMENT OFFICE
EMERGENCY PROCUREMENT REQUEST

1. TO: Chief Procurement Officer

2. FROM: Dept. of Land & Natural Resources, Division of State Parks

Department/Division/Agency

Pursuant to §103D-307, HRS, and Subchapter 10, Chapter 3-122, HAR, the Department requests approval for the following:

3. Date 03/12/07

4. After the fact ☐ YES ☒ NO

5. Nature of the Emergency The Kokee Wastewater Treatment Plan is not operating properly and as such is in violation of Dept. of Health administrative rules. The impellers on the two pumps and the basket used to filter foreign objects entering the system are damaged.

6. Vendor: A-Vac, LLC
Address: 3560 Koloa Road
Kalaheo, HI 96741

7. Price:
\$6,216.63

8. Description of goods, services, or construction to be purchased

Emergency repairs to Kokee Wastewater Treatment Plan: 1) replacement of submersible effluent pumps along with electrical connections, and 2) replacement of the basket.

9. Reason for Vendor Selection

The only available vendor on the island with with Dept. of Health certified wastewater plant operator.

10. Direct questions to: Wayne. H. Souza

Phone: (808) 274-3446

11. I certify that the information provided above is to the best of my knowledge, true and correct.

Department Head or Designee

Date

12. Chief Procurement Officer's comments:

13.

☐ APPROVED ☐ DISAPPROVED ☒ NO ACTION REQUIRED

Chief Procurement Officer

Date

14. E.P.No.